



## *Clivus Multrum Composting Toilet Systems*

### Cleaning and Maintenance of Public Amenities

#### **Cleaning:-**

Clean pedestal and chute using bio-degradable general purpose detergent and a brush. Disinfect surfaces by swabbing over surfaces with disinfectant applied to a damp cloth. **DO NOT POUR DISINFECTANT (including bleach) DOWN CHUTE.**

**You can splash as much water around as you like.**

#### **Maintenance:-** carried out as required for use pattern.

1. **Check that fan is working.** If not, check the power is connected and the fan is not blocked. Replace fan if not functioning.
2. **Rake the pile** to level and loosen the material on top.
3. **Check** that excess liquid **drain is not blocked** and check there is no fluid build up in the bottom of the tank.
4. **Check** that **bilge pump** (if fitted) is working and not blocked. If a daylight solar system is fitted, the pump will not function while there is no sun on the panel.
5. **Add up to 3 buckets** of loose organic matter per chamber (depending upon use patterns) to top of pile via the pedestal/s. **Wood shavings from a cabinetmaker (not sawdust) or sugarcane mulch** are ideal.
6. **Remove finished compost** from bottom access door, **but only if the level of the pile is approaching the top access door.** Only remove enough to allow the pile to settle to an acceptable height.

**NEVER EMPTY THE UNIT.**

#### **Problems?**

Contact Grant Webster - 0411 29 66 42